

SEWERS AND SEWAGE DISPOSAL

18 Attachment 1

Township of East Rockhill

Appendix A

1. Typical domestic levels for compatible pollutants shall be:

Parameter	Maximum Concentration (mg/l)
Biochemical Oxygen Demand (BOD ₅)	250(1)
Total Suspended Solids (TSS)	250(1)
Phosphorus (Total)	10 as P(1)
Total Kjeldahl Nitrogen (TKN)	40 as N(1)

2. No user shall contribute toxic pollutants to the PWTA sewer system in excess of the local limits identified in the PWTA's most recent USEPA-approved local limits evaluation. The approved local limits evaluation is available for public inspection at the offices of the Authority, 180 Maple Avenue, Sellersville, Pennsylvania, during the regular business hours of the PWTA. At its discretion, the PWTA may establish alternate mass limits for specific toxic pollutants in individual wastewater contribution permits, but only in accordance with regulatory requirements. At no time shall the total loading allocated to the users in their permits for a specific pollutant be greater than the allowable wastewater treatment plant industrial loading as determined in the PWTA's most recent USEPA-approved local limits evaluation. The local limits, if more stringent than the National Categorical Standards, shall supersede the National Categorical Standards.

- A. Users may exceed the maximum concentration listed for these parameters but will be surcharged according to the PWTA High-Strength Surcharge Formula. Copies of this formula can be obtained from the PWTA Manager.
- B. (Reserved)
- C. The PWTA, at its sole discretion, may develop best management practices (BMPs) to comply with 40 CFR 403.5(c)(1). Such BMPs shall be considered local limits and pretreatment standards for the purposes of 40 CFR 403 and Section 307(d) of the Clean Water Act. The PWTA, also at its sole discretion, may allow a user to implement BMPs to meet the prohibitions listed in 40 CFR 403.5(a)(1) and (b) and § 18-211 of this Part. BMPs may also be implemented in addition to an approved limit or prohibition. If BMPs are allowed, they will be implemented through user permits. Authorization of BMPs, in place of or in addition to approved limits or prohibitions, does not relieve the user of responsibility to comply with approved limits or prohibitions.

(Ord. 156, 4/26/1994; as amended by Res. 98-9, 4/28/1998; by Ord. 176, 4/28/1998, §§1,2; by Res. 2002-03, 2/19/2002; and by Ord. 264, 8/16/2011)